



CARLISLE'S
GeoMembrane

SAMPLE

Carlisle SynTec Incorporated
1201 Scott Street, Industrial Park, Senatobia, MS 38668
Tel: 888-215-7975 Fax: 662-562-4283 www.carlisle-syntec.com

CERTIFICATION OF CONFORMANCE

TO: WATERSAVER COMPANY, INC
5870 EAST 56TH AVENUE
PO BOX 16465
DENVER CO 80022-3932
US

DATE: 01/05/2009

SAMPLE

ORDER NUMBER: 616915 PRODUCT CODE: 303931 .036 RE. GEOPOT BLACK PP 12' X 600' (JJB)

Property	Lot number	Z97MJB	0ZUYQB		
	Roll Number	1-26	10		
	SPECIFICATION	REPORTED VALUES ¹	REPORTED VALUES ¹	REPORTED VALUES ¹	REPORTED VALUES ¹
Thickness (nominal) (mils)	36	39	38.9		
Thickness (minimum) (mils)	32.4				
Weight per Unit Area (g/sf)	74	87	81		
Tensile Properties					
Grab Strength (lb/4")	200				
Machine Direction		266	263		
Cross Direction		258	262		
Grab Elongation (%)	22				
Machine Direction		27	27		
Cross Direction		27	27		
Tear Resistance (min. ave.) (lb)	75				
Machine Direction		104	113		
Cross Direction		119	83		
Ply Adhesion (lb or FTB)	20 lbs or UTSP	UTSP	UTSP	UTSP	UTSP

¹ Values reported are statistically determined from all rolls shipped for this order.

This document certifies that the product listed above conforms to all requirements specified in the appropriate Technical Data Bulletin.

QA: D. Burdette
Senior Quality Technician

DATE: 1.05.09

SAMPLE

* FOR QUESTIONS OR INFORMATION, PLEASE CONTACT OUR TECHNICAL DEPARTMENT AT 888-215-7975.